



Suitability Test Report
Issued To:
Safety Padding, LLC
4781 N U.S. Highway 51
63 E Broad St
Hatfield, PA 19440
USA

Standard:
Suitability Test Report of a Indoor Wall Padding System According to
ASTM F2440 (2010)

System Name:
SP-Impact Series

Date of Suitability Testing	Feb 15, 2021
Suggested Retest Date	Feb 15, 2023
Report Number	F2440-021521-01
Pages	7

Evaluated Characteristic of ASTM F2440	Average	Maximum	Maximum Allowed	Result
Gmax	103	109	200	Pass
HIC	445	487	1000	Pass

Notes:

1 – Key construction details are highlighted in Section 1 (page 3) of this report. Specifications and installation instructions containing these key details have been supplied and reviewed. Necessary tools and methods to achieve proper anchoring have also been addressed in the specification and installation instructions.

2 – This document contains enhanced digital and duplication security features. More information can be found on our website: www.asetservices.com/blog.

3 – This report contains 7 pages, and may not be used for commercial purposes unless it is reproduced in its entirety.